

## Tower Lighting RFP Addendum 1

*An updated scope of work was posted on the Sauk County website on 1-2-2024*

### Questions:

1. Is this a Davis Bacon or Prevailing Wage Project?
  - a. **No, the scope of work does not have a prevailing wage.**
2. Does the county have pictures of the towers/sites?
  - a. **Sauk County has pictures, however they will not be provided as a part of the Addendum.**
3. The bid mentions a bid and performance/payment bond. This is not going to be an overly costly project. Does the county have a minimum threshold where the bonds are not required?
  - a. **A bond is required per the Standard Terms and Conditions.**
4. Does the kit provide a fastener kit, is weatherproof tape or cable banding to attach the fiber and power wire?
  - a. **Steel banding is the preferred method to attach the cabling to tower legs. The use of snap ins on cable guides is also acceptable.**
5. Can existing conduit be used on a tower?
  - a. **Yes, existing conduits can be used if available.**
  - b. **Weather tight fittings at the various junction boxes need to be used.**
6. Is an electrical permit required for sites?
  - a. **No electrical permit is needed.**
7. Will the County notify air fields when lights are turned off?
  - a. **Contractor is to notify air fields based on work schedule at each tower site.**