

SAUK COUNTY COURTROOM AUDIO

ADDENDUM #1

What are the courtroom dimensions:

Branch I: 30' X 50' with a ceiling height of 12'

Branch II: 31' X 52' with a ceiling height of 18'

Branch III: 30' X 42' with a ceiling height of 12'

Family Court Commissioner: 20' X 42' with a ceiling height of 16'

Who will be coordinating possible floor coring?

The selected vendor will be coordinating any needed floor cores. It is preferred that coring take place prior to the start of the courts day at 8:30 am or after court has finished for the day around 4:30 pm. Office space with open ceiling is below each potential floor coring spot.

How many outputs are needed to connect with the Digital Audio Recording (DAR) system?

Four (4) individual outputs from the mixer to the DAR system at the clerk station. Inputs include:

Judge, Defendant, Prosecution, Witness/Telephone input

Will program (audio from video evidence, audio evidence, etc) be required as well?

Program audio as a 5th input for the DAR system would be accepted.

Will TV screens need to be factored into Vendor's bid?

No, the current televisions will be re-used in the courtrooms. Data wiring should be pulled for a future tv in the Family Court Commissioner's courtroom.

Will work be able to be done during normal business hours?

Yes, the majority of the work can and should be completed during normal business hours. Building Services has staff onsite from 6:30 am until 4:30 pm Monday through Friday.

Are the data racks to be wall-mounted racks required or just preferred?

Wall mounted racks are preferred in all three circuit branch courts. The Family Court Commissioner system must be a two post floor mounted rack due to the mounting location.

Who would be responsible for any necessary pathways?

The selected vendor is responsible for creating the pathways. Sauk County Building Services is willing to assist in helping determine the best path. Vendor will be responsible for any drywall patching, touch up painting, and clean-up if any cutting of drywall or plaster walls/ceilings are necessary.

Are speakers allowed to be mounted in drywall ceilings where there currently are none?

Speakers can be added into drywall/plaster surfaces if needed.

In the Family Court Commissioner's courtroom, there are surface-mounted speakers existing. Are similar surface-mounted speakers preferred?

Yes, Sauk County prefers to keep wall surface mounted speakers in the Family Court Commissioner's courtroom.

Would ceiling-suspended pendant speakers be allowed?

No, Sauk County does not want suspended pendants in the Family Court Commissioner or Branch II courtrooms.

Is an existing pathway available in that center decorative ceiling?

Yes, an existing pathway is available. Plenum rated cable will need to be ran in this area. Plenum rated cable should be ran throughout the entire project pathway..

Are surface-mount raceways acceptable if necessary and no in-wall path can be identified?

Yes, the surface-mount raceways will need to be paintable.

Additional power will be necessary at rack and proposed display locations.

Power is available at the proposed locations. If more power is needed, Sauk County will get the required power to the location.

Are you willing to consider using 2 mics at Defense and 2 mics at Prosecution?

Yes, Sauk County is open to this option.

Digital wireless mics allow for encryption and greater security. Is this a concern for the requested wireless mics?

This is not a concern, as the wireless microphones will be used mostly during Jury trials for opening and closing arguments.

Will the telephone interface be analog or IP? Or both?

The telephone will need to interface for both. Sauk County is transitioning to *AVAYA 8.1* software in the *fall of 2019*. The courtroom phones will be upgraded after the software upgrade is completed.

Do you want the ability to dial phone numbers from the control panel on the judge's bench?

This feature would be nice, but is not necessary. This can be added in as an alternate in the final pricing.

Is there a preferred zoning for each room?

No, Audio zoning is not necessary for this audio system.

Is the shielded Cat 6 requirement at the prosecution and defense tables to be a network connection?

No, plenum rated Cat 6 cable is the only requirement.