

WISCONSIN CONSTRUCTION SPECIFICATION

2. Excavation

1. SCOPE

The work shall consist of the excavation of all materials necessary for the construction of the work.

2. USE OF EXCAVATED MATERIALS

To the extent that they are needed, all suitable materials removed from the specified excavations shall be used in the construction of the required earthfill. The suitability of materials for specific purposes will be determined by the Technician. The Contractor shall not waste or otherwise dispose of suitable excavated materials.

3. DISPOSAL OF WASTE MATERIALS

All surplus or unsuitable excavated materials will be designated as waste and shall be disposed of at the locations shown on the drawings or as approved by the Technician. Waste materials shall not be placed in wetlands.

Material placed in designated waste disposal areas shall be left in a neat and sightly condition and sloped to provide positive drainage. Compaction of the waste materials will not be required unless specified by the construction plans.

Waste material excavated from channels may be deposited in leveled spoilbanks or areas adjacent to the channel work (if permissible). The shape and slopes of the spoilbanks shall be indicated on the drawings or as approved by the Technician. Spoil piles shall be located a minimum of 12 feet from the top of the channel side slope.

Spoil piles or disposal areas shall be protected to minimize site erosion and the production of sediment. Protective measures may include but are not limited to diversions, seeding, mulching, sediment basins, and silt fences.

4. SPECIAL REQUIREMENTS FOR STRUCTURE AND TRENCH EXCAVATION

The required dimensions and side slopes of all structure and trench excavations shall be as shown on the drawings.

Excavation beyond the limits of the specified lines and grades shall be corrected by filling the resulting voids with approved compacted materials.

Excavation for the installation of pipes shall follow the practices contained in the Occupational Safety and Health Administration (OSHA) Subpart P, Excavation, of 29 CFR 1926.650, .651 and .652.

Side slopes shall be excavated or braced to safeguard the work and workers. When bracing or supporting is required, the width of the excavation shall be adjusted to allow for the space occupied by the sheeting, bracing, or other supporting installations. The Contractor shall furnish, place, and subsequently remove such supporting installations.

5. REMOVAL OF WATER

The Contractor shall construct and maintain all necessary cofferdams, channels, flumes, pumping equipment, and/or other temporary diversion and protective work for dewatering the various parts of the work. Foundations, cutoff trenches, and other parts of the work shall be maintained free from water as required for constructing each part of the work. After having served their purpose, all cofferdams and other temporary protective works shall be removed, or leveled to give a sightly appearance and so as not to interfere in any way with the operation, usefulness, or stability of the permanent structure.

6. BORROW EXCAVATION

When the quantities of suitable materials obtained from specified excavations are insufficient to construct the specified fill portions of the permanent works, additional materials shall be obtained from the designated borrow areas.

When shown on the drawings, sediment basins, terraces, diversions, or other measures shall be constructed to protect the borrow areas from erosion and retain sediment within the borrow area.

The upper six (6) inches shall be stripped from all borrow areas. This stripping shall be performed immediately prior to use of the borrow material to reduce the time the area is exposed to erosion. For large borrow areas, only a portion of the area should be stripped at a time. This material shall be redistributed over the area from which it came after borrow excavation is completed.

The extent of excavation and the selection of materials from the borrow area shall be as directed by the Technician. On completion of excavation, all borrow pits shall be left in a neat and sightly condition. All borrow areas shall be graded to blend with existing topography and sloped to prevent ponding and provide positive drainage.

WISCONSIN CONSTRUCTION SPECIFICATION

7. Mobilization and Demobilization

1. SCOPE

The work consists of the mobilization and demobilization of the Contractor's forces and equipment necessary for performing the work required.

2. EQUIPMENT AND MATERIAL

Mobilization shall include:

- All activities and associated costs for transportation of the Contractor's personnel, equipment, and operating supplies to the site;
- Establishment of offices, buildings, and other necessary general facilities for the Contractor's operations at the site
- Premiums paid for performance and payment bonds including coinsurance and reinsurance agreements as applicable
- Construction and maintenance of haul roads and equipment parking areas
- Other job related items

Demobilization shall include:

- All activities and costs for transportation of personnel, equipment, and supplies not utilized in the project from the site
- Disassembly, removal, and site cleanup of offices, buildings, and other facilities assembled on the site.
- Repair of access roads, temporary haul roads, and equipment parking areas leaving the project site in the same or better condition than at the start of the project.
- General cleanup and house keeping needed to restore a neat and orderly project site.

Access to the site, equipment parking, and staging areas are limited to that shown on the drawings or as approved by the technician.

WISCONSIN CONSTRUCTION SPECIFICATION

9. ROCK RIPRAP

1. SCOPE

The work shall consist of testing, furnishing, transporting, and placing rock riprap, including filter, bedding or geotextile materials where specified, in the construction of loose rock riprap revetments, blankets, rock toes, crossings, rock chutes, channel linings and other similar structures.

2. QUALITY OF MATERIALS

The rock shall be obtained from tested sources unless exempted below. Rock sources used for streambank protection, lined waterways, rock chutes, or other similar major projects (Job Class II and above) shall be tested prior to use. A test is required a minimum of every ten (10) years. The Technician may require a more current test.

Rock riprap from igneous or metamorphic origins such as granite, basalt, and quartzite may be used without testing. Dolomite from quarries within the map legend units shown in Figure 1 may also be used without testing:

- Dolomite (Sd) - all counties.
- Sinipee Group (Os) and Prairie du Chien (Opc) exempt only in the following counties: Marinette, Oconto, Shawano, Brown, Outagamie, Calumet, Winnebago, Green Lake, and Fond du Lac.

The Technician shall inspect and approve sources of these rock types prior to use and determine if testing is required.

Rock for equipment or cattle channel crossings, access roads, heavy use area protection or similar minor structures need not be tested.

Individual rock fragments shall be dense, sound and free from cracks, seams and other defects conducive to accelerated weathering. The rock fragments shall be angular to subrounded in shape. The least dimension of each individual rock fragment shall be not less than one-third the greatest dimension of the fragment. It should also be free from dirt, clay, sand, rock fines and other materials not meeting the gradation limits. Rock shall be excavated, selected and handled as necessary to meet the grading requirements stated in the construction plans.

Representative samples of rock requiring testing shall conform to the following requirements:

Bulk Specific Gravity (saturated surface-dry basis). Not less than 2.50 when tested in accordance with ASTM Specification C 127 on samples prepared as described for soundness testing.

Absorption. Not more than four (4.0) percent when tested in accordance with ASTM C 127 on samples prepared as described for soundness testing.

Soundness. The weight loss in five cycles shall not be more than 28 percent when tested by the sodium sulfate soundness test method in the modified ASTM C 88. Losses in excess of 20 percent are acceptable only when the design D₅₀ rock size has been increased by 10 percent for a loss of 20-23.9 percent or 20 percent for a loss of 24-28 percent.

3. METHODS OF TESTING

Bulk Specific Gravity and Absorption shall be determined by ASTM C 127 on samples prepared as described for rock cube soundness testing.

Rock Cube Soundness. Soundness testing shall be performed by ASTM C 88 for coarse aggregate modified as follows.

The sodium sulfate soundness test shall be performed on a test sample of 5000 ± 300 grams of rock fragments, reasonably uniform in size and cubical in shape and weighing, after sampling, approximately 100 grams each. The test sample shall be obtained from rock samples that are representative of the total rock mass, as noted in ASTM Specification D 4992, and that have been sawed into slabs as described in ASTM Specification D 5121. The samples shall be further reduced in size by sawing the slabs into cubic blocks. The thickness of the slabs and the size of the sawed blocks shall be determined by the size of the available test apparatus and as necessary to provide, after sawing, the approximate 100 gram samples.

Due to internal defects, some of the cubes may break during the sawing process or during the initial soaking period. Cubes that break during this preparatory process shall not be tested. Such breakage, including an approximation of the percentage of cubes that break, shall be noted in the test report.

After the sample has been dried, following completion of the final test cycle and washing to remove the sodium sulfate, the loss of weight shall be determined by subtracting from the original weight of the sample the final weight of all fragments which have not broken into three or more fragments. (Samples that break into three or more large fragments during testing will be assigned a final weight of 0.0.) The test report shall show the percentage loss of the weight. Photographic documentation of all samples before and after testing shall be part of the test report.

Equivalent AASHTO testing specifications may be substituted for ASTM testing specifications.

A rock source may be rejected if the rock from that source deteriorates in less than 5 years under similar use and exposure conditions expected for the rock to be installed under this specification, even though it meets the testing requirements stated above.

Deterioration is defined as the visual loss of more than one-quarter of the original rock volume, or severe cracking that would cause a rock to split.

4. GRADATION

The gradation of the rock riprap and filter or bedding material shall be as shown in the construction plans.

Rock used for streambank protection, lined waterways, rock chutes, or other similar major projects (Job Class II and above) shall have a gradation verification be done by one of the following methods.

Method A

Measurement of a random truck load of stone (reference sample) according to the procedure outlined in EFH-17, Procedure for Determining Rock Weights, Sizes, and Gradations; or ASTM D5519, Standard Test Methods for Particle Size Analysis of Natural and Man-Made Riprap Materials (Test Method A).

Method B

Creation of reference samples of rock of at least 0.5 tons, made according to the procedure outlined in EFH-17 (Tables 1 - 5), creating the envelope limits of the gradation specified.

Control of project gradation will be by visual inspection comparing rock delivered to the reference samples.

The reference sample(s) may be used as part of the finished riprap or remain at the quarry.

Any difference of opinion between the Technician and the Contractor shall be resolved by dumping and checking (by measurement) the gradation of a random truck load of stone by Method A. Mechanical equipment, a sorting site, and labor needed to assist in checking gradation shall be provided by the Contractor at no additional cost.

5. SUBGRADE PREPARATION

The subgrade surfaces on which the riprap, filter or bedding material is to be placed shall be cut or filled and graded to the lines and grades as shown on the drawings or as directed by the Technician. When fill to subgrade lines is required, it shall consist of approved materials and shall be compacted as specified in Wisconsin Construction Specification 3, Earthfill. Riprap, filter, bedding or geotextile shall not be placed until the foundation preparation is completed, and approved by the Technician.

6. FILTER AND BEDDING

Filter or bedding material, when required, shall be spread uniformly on the prepared subgrade surfaces to the depth shown on the drawings. The surfaces of the layers shall be finished reasonably free of mounds, dips or windrows and shall meet the gradation shown on the plans or as specified in Wisconsin Construction Specification 8.

Geotextile, when required, shall meet the requirements shown on the drawings and as specified in Wisconsin Construction Specification 13, Geotextiles.

7. PLACING ROCK RIPRAP

The rock riprap shall be placed by equipment on the surfaces and to the depths specified. The rock riprap shall be installed to the full course thickness in one operation and in such a manner as to avoid displacement of underlying materials. The rock for riprap shall be delivered and placed in a manner that will ensure that the riprap in-place shall be reasonably homogeneous with the larger rocks uniformly distributed and firmly in contact one to another with the smaller rocks and spalls filling the voids between the larger rocks. Some hand placing may be required to provide a neat and uniform surface or to prevent damage to structures.

8. VEGETATED ROCK RIPRAP

If the rock riprap is to be vegetated, topsoil shall be placed by equipment in the riprap voids (surface) and on the surface of the rock to the depth specified. The topsoil placement shall not take place before the placement of the rock riprap is approved by the Technician. Topsoil shall be placed in such a manner as to avoid displacement of the underlying rock.

The topsoil may extend from the top of the riprap down to the bankfull elevation (OHWM) or as shown on the drawings. Care shall be taken so topsoil is retained on the rock and is not allowed into the water body. The area shall be seeded and mulched within 12 hours following topsoil placement.

Figure 1

